


# Quick Menu Driven Programming

How to enter Quick Menu

1. Press the 
2. Installer code  
( default: 0 0 0 0 )

Select menu below

(tip : You can jump between menu's by pressing the keys below)





Table 1: Zone Definitions

Zone Definitions	Stay Arm	Sleep Arm	Fully Arm	Zone Definitions
00 = Zone Disabled (default)	-	-	-	11 = Instant Fire†
01 = Entry Delay 1	Entry Delay 1	Entry Delay 1	Entry Delay 1	12 = Delayed Fire†
02 = Entry Delay 2	Entry Delay 2	Entry Delay 2	Entry Delay 2	13 = Instant Fire Silent†
03 = Entry Delay 1 (Full Arm)	Not Armed	Not Armed	Entry Delay 1	14 = Delayed Fire Silent†
04 = Entry Delay2 (Full Arm)	Not Armed	Not Armed	Entry Delay 2	15 = 24Hr. Buzzer
05 = Follow	Follow*	Follow*	Follow	16 = 24Hr. Burglary
06 = Follow (Sleep/Full Arm)	Not Armed	Follow*	Follow	17 = 24Hr. Hold-up
07 = Follow (Full Arm)	Not Armed	Not Armed	Follow	18 = 24Hr. Gas
08 = Instant	Instant*	Instant*	Instant	19 = 24Hr. Heat
09 = Instant (Sleep/Full Arm)	Not Armed	Instant*	Instant	20 = 24Hr. Water
10 = Instant (Full Arm)	Not Armed	Not Armed	Instant	21 = 24Hr. Freeze
				22 = 24hr. Panic††
33 = Instant No Pre-Alarm (Stay/Sleep)	Instant No Pre-Alarm	Instant No Pre-Alarm	Not Armed	23 = Follow No Pre-Alarm
34 = Instant No Pre-Alarm (Sleep)	Not Armed	Instant No Pre-Alarm	Not Armed	24 = Instant No Pre-Alarm
35 = Entry Delay 1 (Stay/Full) / Instant	Entry Delay 1	Instant No Pre-Alarm	Entry Delay 1	25 = Keyswitch Maintain**
36 = Entry Delay 1 (Full Arm) / Instant	Instant No Pre-Alarm	Instant No Pre-Alarm	Entry Delay 1	26 = Keyswitch Momentary**

\* Flex-Instant = Zone will follow the delay at section [720], (default is 15 seconds / 0 = instant zone)  
 † On-board hardware control panel zones only  
 ‡ ZX8 inputs do not support fire zones.  
 For 2-wire smoke installations (not supported by SP5500), these definitions apply to Zone 1 Input only. Section [706], option [3] must be enabled.  
 For 4-wire smoke installations, use any panel on-board zone input.  
 †† This alarm will follow the Panic 1 option (section [702], option [1])